



Descrizione

Il modulo REI2845 serve per riportare a distanza i segnali di allarme richiesti dalla normativa UNI12845 .

Viene collegato alla centralina antincendio **TE2010vvf** tramite appositi morsetti da cui riceve i segnali di allarme.

Il modulo si autoalimenta tramite una batteria che viene automaticamente mantenuta in carica e assicura che i led di segnalazione di allarme del modulo e del TE2010vvf controller restino accesi anche in caso di mancanza della rete elettrica

Il modulo si compone di:

- ▶ 1-tasto per il test dei leds
- ▶ 1-tasto di tacitazione sirena
- ▶ 1-led di modulo alimentato
- ▶ 1-led carica batteria in funzione
- ▶ 1-led allarme richiesta avviamento
- ▶ 1-led di allarme mancato avviamento
- ▶ 1-led di allarme in funzione
- ▶ 1-led di allarme guasto del quadro elettrico

EN -61010



Description

The RE12845 module is used to report the alarms requested by UNI12845 normative. It must be connected to the **TE2010-VVF** firefight controller from which it receives the alarms signals.

The module is self-supplied by a battery that is automatically kept charged and ensures that the alarm leds of the module and of the TE2010-VVF controller remain ON even in case of mains lacking.

The module is composed by:

- ▶ 1-button for the test of the leds
- ▶ 1-button for siren silencing
- ▶ 1-led for supply connection
- ▶ 1-led for charging procedure
- ▶ 1-led for "start request" alarm
- ▶ 1-led for "start failed" alarm
- ▶ 1-led for "pump ON" alarm
- ▶ 1-led for "NO supply" alarm